




Config Com2 as Modbus-RTU,9600,8,N,1



PM-RT12 Station Number setting  
PM-RT12: Station1



PM-RT12 address settings  
Read:  
D1480 = CH1 Low Word  
D1481 = CH1 High Word  
D1482 = CH2 Low Word  
D1483 = CH2 High Word  
Write: None



Enable / Disable the Slave ID#  
for example, if M1360 = OFF, ID 1 is Disabled



